

OFFICE OF THE PUBLIC HEALTH ENGINEERING DEPARTMENT
SUB DIV SURAJGARH

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No.: 89

Dated: 22-05-26

It is certified that an inspection team headed by **AEN PHED Sub Div. Surajgarh Mr. Avinash Kajla** (A.En.) from Sub Div. Surajgarh (Jhunjhunu) PHED inspected the Tagore Public School, Surajgarh Jhunjhunu (Raj.) On 22-5-2026 and on the basis of Water Test Report bearing **No.Lab./Chem./2026-27/184** Dated 22-05-2026 of Jhunjhunu.(PHED Lab) Certified that the **Tagore Public School, Surajgarh.** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till 06 months (22-05-2026 to 22-11-2026)

To
The Principal
Tagore Public School Surajgarh
Dist. Jhunjhunu (Raj.)
Ph. No. 9460842844


सहायक अभियन्ता
Signature with Seal
Name: स्व. अभि. Avinash Kajla
Designation: Assistant Engineer

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2026-27/ 184

Date - 22-5-2026

To,

The Principal
Tagore Public School
Surajgarh

District - Jhunjhunu
Tehsil - Surajgarh
Date of Exam - 22.05.26

Ref- Your letter no. 88 dated 22.05.26

A	Name & Location of Source	IS-10500:2012		Water Sample Tagore Public School
B	Village/ Town			Surajgarh
C	Date Of Collection			22-05-26
D	Lab. Sample No.			C-052
Sr. No	Parameters	Desirable limits	Permissible limits	Value
1	pH	6.5—8.5	6.5—8.5	7.16
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Residual Chlorine	0.2	1.0	Nil
7	Total Alkalinity[asCaCO ₃]	200	600	70
8	Total Hardness[asCaCO ₃]	200	600	28
9	Chloride[asCl ⁻¹]	250	1000	36
10	Nitrate[as NO ₃ ⁻¹]	45	45	05
11	Fluoride [as F ⁻¹]	1.0	1.5	0.20
12	Sulphate [as SO ₄ ⁻²]	200	400	12
13	TDS	500	2000	166

Note:1- All Results Except pH in mg/L.

2- This report is not valid for legal cases/legal purposes.

(S K Sharma)
Junior Chemist
PHED Laboratory Jhunjhunu